



**NOTES:**

1. SIZES SHALL BE VERIFIED BY THE DEVELOPERS ENGINEER.
2. BACKFLOW PREVENTERS SHALL BE REDUCE PRESSURE PRINCIPLE ASSEMBLIES WHEN LINES ARE CONNECTED TO HIGH HAZARD USES IN ACCORDANCE WITH CITY OF KANNAPOLIS CROSS CONNECTION CONTROL POLICY.
3. 1-1/2" & LARGER DOMESTIC METER SHALL BE INSTALLED WITH GATE VALVE.



**KANNAPOLIS**  
PUBLIC WORKS

**WATER SERVICE  
TYPICAL FIRE LINE CONNECTION**

DATE: 7 JUNE 13

**W-WS-04**